




XL

XL*, XDL*



XA-1

XS-1
XA1XC
XS1

NEMA

Class 8501

Mechanical Latch
Attachment
Manual Test Tool
Transient Suppressor

Type	AC Voltage-Hz	*Code	Type	Description
XL*	24-60	U01	XA1	Manual Test Tool, Holding Contacts in Switched State during Check
	120-60/110-50	2		
	240-60/220-50 Other Voltage	U03 U99		
	DC Voltage		XS1	Transient Suppressor, Suppression of Coil Generated Transients, for Use on 120VAC Coils only
XDL*	115/125 Other Voltage	U62 U99		